

Letter No: BIIRDP/0374/01/2026 Approved Date: 22-01-2026

Dr. Munira Shukla
Chief District Health Officer,
Bharuch.



Health Branch
District Panchayat
Bharuch - 392001
Ph.No. : 02642-243000
E-mail : rdho.health.bharuch@gmail.com

APPENDIX-VIII

SAFE DRINKING WATER AND SANITATION CONDITION CERTIFICATE

No. 9

Date: As per e-Sign

It is certified that an inspection team headed by Chief District Health Officer from Dept. Of Health, Dist. Panchayat Bharuch inspected the RUNGTA VIDYA BHAVAN, Near Rotary Club, Mahatma Gandhi Road, Bharuch-392001 on 19-01-2026 and found that RUNGTA VIDYA BHAVAN has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above certificate is valid for a period upto 31-12-2026.

e-sign

Chief District Health Officer
District Panchayat Bharuch

To,

RUNGTA VIDYA BHAVAN,
Near Rotary Club, Mahatma Gandhi Road,
Bharuch-392001.

Signature Not Verified

Signed by Dr. Munira Shukla
Additional District Health Officer
Date 2026 01 22
17 08 16 +5 30

File No: BIIRDP/ADM/c-file/620/2026/0532/Health

Approved By: Additional District Health Officer, Health, BIIRDP

Open the document in Adobe Acrobat DC to verify the E-sign



1/1


CAMPUS DIRECTOR
RUNGTA VIDYA BHAVAN
BHARUCH-392001


PRINCIPAL
RUNGTA VIDYA BHAVAN
BHARUCH.



District Laboratory
Bharuch, Gujarat Water
Supply And Sewerage
Board, 1st Floor, Old
Collector Office, Kanbi
Waga, Bharuch-392001



E mail :
distlabharuch@gmail.com

જિલ્લા પંચાયતના ભરૂચ,
ગુ.પા.પુ.અનેગ વ્યા.બોર્ડ, પહેલો
માળ, જુની કલેક્ટર ઓફિસ, કાંબી
વગા, ભરૂચ-૩૯૨૦૦૧



DL/7.8/F-01

Test Report

Name & Address of Customer*:-		Customer Reference No. *	Nilid. 25.08.2026
Rungta Vidya Bhavan		Sample Submitted by	Customer
Station Road		Date of Sample Receipt	25.08.2026
Rotary Club		Analysis Starting Date	27.08.2026
Ta:-Bharuch		Analysis completion Date	27.08.2026
Bharuch		ULR No	TC177762600001289F
		Discipline	Chemical Testing, Group: Water
		Date of Issue	29.08.2026
		Source *	R O Treated Water
		Condition Of Sample	Satisfactory
Test Report No	1289/2026-27		
Sample ID	BCW-1289/08-26		
Main Source *	Municipality Water		
Location *	At Rungta Vidya Bhavan		
Village*	Bharuch	Habitation*	Bharuch
Taluka *	Bharuch	District*	Bharuch
Latitude *	--	Longitude*	--
		Sample Type	Drinking Water

Kindly find herewith the Analytical Results.

Sr. No.	Parameter	Unit	Value as per IS 10500 : 2012 [2 nd Revision]		Reference Method :	Analytical Value
			Requirement (Acceptable Limit) Max.	Permissible Limit in the Absence of Alternate Source Max.		
1	Colour	Hazen	5	15	APHA 24 th (Method 2120 B)	5
2	Odour	-	Agreeable	Agreeable	IS 3025 (Part 5) - 2022 (Second Revision)	Agreeable
3	Taste	-	Agreeable	Agreeable	IS 3025 (Part 8) - 2023	Agreeable
4	Turbidity	NTU	1	5	APHA 24 th (Method 2130 B)	0.23
5	pH at 25°C	-	6.5 to 8.5	No relaxation	APHA 24 th (Method 4500 H ⁺ B)	7.34
6	Conductivity at 25°C	µS/cm	-	-	APHA 24 th (Method 2510 B)	227
7	Total Dissolved Solids	mg/l	500	2000	APHA 24 th (Method 2540 C)	124
8	Total Hardness(as CaCO ₃)	mg/l	200	600	APHA 24 th (Method 2340 C)	94
9	Calcium (as Ca ⁺²)	mg/l	75	200	APHA 24 th (Method 3500 Ca ⁺² B)	21
10	Magnesium (as Mg ⁺²)	mg/l	30	100	APHA 24 th (Method 3500-Mg ⁺² B)	29
11	Chloride (as Cl ⁻)	mg/l	250	1000	APHA 24 th (Method 4500-Cl ⁻ B)	64
12	Sulphate (as SO ₄ ⁻²)	mg/l	200	400	APHA 24 th (Method 4500-SO ₄ ⁻² E)	17.53
13	Fluoride (as F ⁻)	mg/l	1	1.5	APHA 24 th (Method 4500-F ⁻ C)	0.18
14	Total Alkalinity (as CaCO ₃)	mg/l	200	600	APHA 24 th (Method 2320 B)	88

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used as evidence in court of law.
4. Please refer Front page for IS 10500:2012 (2nd Revision) limits.
5. Disclaimer : Information marked by " * " is provided by the customer.

Authorized Signatory
VIRENSINH M.RAJ

End of the Test Report

CAMPUS DIRECTOR
RUNGTA VIDYA BHAVAN
BHARUCH-392001

PRINCIPAL
RUNGTA VIDYA BHAVAN
BHARUCH-392001



DISTRICT LABORATORY Bharuch
Gujarat Water Supply Sewerage Board,
1st Floor Right Wing, Old Collector Office, Kanbiwaga, Bharuch.



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER	
Name & Address Rungta Vidya Bhavan Station Road Rotary Club, Bharuch	
Sender's Ref. No.: Nil/dt 25.08.2026	
Ref. Date: 25.08.2026	
Date & Time of Commencing Examination 25.08.2026	
Sample collected by: Customer	
BW No.	1297
Date of Collection	25.08.2026
Date of Arrival at Lab.	25.08.2026
Source of Water Sample & Location	R.O. Treated water At Rungta Vidya Bhavan
Village	Bharuch
Habitation	Bharuch
Taluka	Bharuch
District	Bharuch
APHA, AWWA, 9221-D Presence - Absence Coliform Test, @ 37° C	A
APHA, AWWA, 9221-F Presence - Absence E-Coli Test, @ 37° C	...
MPN of coliform per 100 ml of sample at 37° C	<2
MPN of Faecal coliform per 100 ml of sample at 44° C	<2
Free Chlorine (PPM)	Nil
OPINION FOR POTABILITY :	FIT
Important Note:- 1) '>=' Indicates greater than or equal to, 2) '<' Indicates less than NOTE : Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Revision. @ All Water Intended for Drinking - (a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample @ Treated Water Entering the Distribution system & Treated Water in the Distribution system - (a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample (b) Total coliform bacteria shall not be detectable in any 100ml sample. @ 0.2ppm Free Residual Chlorine at consumer end is recommended. 1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only. 2) This Report should not be taken as a basis to getting license from any Government authority 3) After Collection of Bact. Sample, It must be preserved at 4°C and submitted to laboratory within 24hrs	
 Authorized Signatory	

CAMPUS DIRECTOR
RUNGTA VIDYA BHAVAN
BHARUCH-392001

PRINCIPAL
RUNGTA VIDYA BHAVAN
BHARUCH 392001