

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITATION CONDITION
CERTIFICATE**


No. 294

Date : 30-04-2024

It is certified that an inspection team headed by Dr. J. S. Dulera, Chief District Health Officer from DEPT. OF HEALTH, DIST. PANCHAYAT BHARUCH, inspected the RUNGTA VIDHYA BHAVAN, Near Rotary Club, Mahatma Gandhi Road, Dist. Bharuch - 392001, Gujarat. on 03-05-2024 and found that the RUNGTA VIDHYA BHAVAN, Near Rotary Club, Mahatma Gandhi Road, Bharuch - 392001, Gujarat. has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period upto **31-12-2024.**




Signature with Seal
Name: Dr. J. S. Dulera
Designation: CDHO

To.

Principal,
RUNGTA VIDHYA BHAVAN
Near Rotary Club, Mahatma Gandhi Road,
Dist. Bharuch - 392001,
Gujarat.

BHARUCH MUNICIPALITY, BHARUCH

Nr. CIVIL HOSPITAL, STATION ROAD, BHARUCH
(STD CODE-02642) (O) 220143, 243525 (F) 241753
email : np_bharuch@yahoo.co.in



Ref. No. અનેટરી/૧૩

Date : ૨૬ /04/2024


Safe Drinking Water and Sanitary condition Certificate

It is certified that an inspection by Mr. Yuvrajsinh N Sayaniya, Chief sanitary Inspector from DEPT, OF SANITAION, BHARUCH MUNICIPALITY, BHARUCH inspected the **RUNGTA VIDYA BHAVAN, BHARUCH Near Rotary Club, Mahatma Gandhi Road, Bharuch – 392001 Gujarat** on Dtd. 26-04-2024 and found that the RUNGTA VIDHYA BHAVAN, BHARUCH has safe drinking water facilities forthe students and members of staff of the institution and is maintaining the hygienicsanitation condition in the school building & the campus as per the norms prescribedby the Central/State/U.T Govt.

The above valid for a period upto 31-12-2024.

Signature with Seal




Harish Agraval
Chief Officer
Bharuch Municipality
Bharuch.

To.

Principal,

**RUNGTA VIDYA BHAVAN, BHARUCH Near Rotary Club, Mahatma Gandhi Road,
Bharuch 392001, Gujarat**

**Test Report for Drinking Water**

Test Report No.	: GGR/BWA/9186/03/2023-24	Report Generate Date	: 07-03-2024
Name of Client	: Rungta Vidhya Bhavan		
Address	: Station Road, Bharuch		544
Name of Consultant	: --		
Project Site	: --		
Name of Work	: --		
Date of Sample Receipt	: 06-03-2024		
Condition of Sample	: Satisfactory		
Letter Reference No.	: Letter No. : Nil, Dated : 06-03-2024		
Sample Source/Brand	: RO Water.		
S Specification	: IS : 10500 : 2012	Method of Test	: Part of IS : 3025

Physical Test Results

Sr. No.	Types of Test	Method of Test	Test Result	Requirement as Per IS : 10500 : 2012
1.0	Colour, Hazen Unit	IS : 3025 Part-4	Colour Less	5.0 Max.
2.0	Odour	IS : 3025 Part-5	Odour Less	Unobjectionable
3.0	Turbidity, NTU	IS : 3025 Part-10	0.784	1.0 Max.
4.0	pH	IS : 3025 Part-11, Parts-7 & 8	7.813	6.50 - 8.50
5.0	Total Alkalinity as Calcium Carbonate	mg/l IS : 3025 Part-23	120.0	200.0 Max.
6.0	Total Hardness (as CaCO ₃)	mg/l IS : 3025 Part-21	131.0	200.0 Max.
7.0	Calcium (as Ca)	mg/l IS : 3025 Part-40	34.0	75.0 Max.
8.0	Magnesium (as Mg)	mg/l IS : 3025 Part-46	29.0	30.0 Max.
9.0	Chloride (as Cl)	mg/l IS : 3025 Part-32	128.0	250.0 Max.
10.0	Sulphate (as SO ₄)	mg/l IS : 3025 Part-24	121.0	200.0 Max.
11.0	Fluoride (as F)	mg/l IS : 3025 Part-60	0.79	1.0 Max.
12.0	Nitrate (as NO ₃)	mg/l IS : 3025 Part-34	Absent	45.0 Max.
13.0	Total Dissolved Solids	mg/l IS : 3025 Part-16	133.0	500.0 Max.

Remark : The Water is FIT for Drinking purpose as per IS : 10500:2012.**Checked by** : Mr. Raj Nigudkar**Designation** : Quality Manager.**Authorised Signatory**

Devanshi Intwala
(Director)

*** End of Report *****Note** : The Sample were Submitted by Customer.

: Details as Furnished by the Customer.

: The Results Relate Only to the Samples Tested.

: The Test Report Shall Not be Reproduced Except in Full, Without Written Approval of the GGR.



Siddhi Green Excellence

PRIVATE LIMITED

TEST REPORT

544

Date of Issue : 07-03-2024

REPORT NO. : SC/RVB/DW/MAR/2024/01

Issued to	M/s. RUNGTA VIDHYA BHAVAN
Address	RUNGTA VIDHYA BHAVAN, STATION ROAD, BHARUCH

Sample Details	Sample 1	Total No. of sample received	1
Type of sample	Drinking Water Sample	Date of Sampling	06-03-2024
Sample ID	M-6564-DW-01	Date of Receipt	06-03-2024
Sample Qty. & Packing	100 mL in sterilised bottle	Date of Analysis start	06-03-2024
Batch No./Lot No.	Not Specified	Date of Completion	07-03-2024
Sampled by	Client		

Sampling Plan & Sampling method used: As per SC/LAB/01

SR. NO.	PARAMETERS	UNIT	TEST METHOD	PERMISSIBLE LIMIT AS PER IS:10500:2012 (DRINKING WATER)	RESULTS
					SAMPLE 1
1	Total Coliform	CFU/100 mL	IS 15185:2016	Shall not be detected in any 100 mL sample	Absent /100mL
2	E.coli	CFU/100 mL	IS 15185:2016	Shall not be detected in any 100 mL sample	Absent /100mL

Additions to, deviations, or exclusions from the method: None

Results from external providers, if any: None

Any other remarks: Sample received from Gayatri geotechnic research

Abbreviations Used: CFU- Colony Forming Unit

Verified By	For SIDDHI GREEN EXCELLENCE PRIVATE LTD.
	Mrs. K. P. Shah/ Mrs. M. Shah

Notes : 1. Test results shall be referred to the tested sample(s) only and applicable parameter(s) only.

2. Permissible limits if mentioned in report are given by customer and included in the report upon request by customer.

3. Certificates of accreditation are available on lab's website with period of validity. If non-accredited parameters are analysed, their results are given on next page.

4. The opinions and interpretations if mentioned in report are given upon request by customer and based upon material and information supplied by customer.

5. Perishable samples will be disposed after testing, For microbiological tests, if retest of sample is desired for any test/s, it is recommended to send duplicate sealed samples in sterile containers with adequate quantity.

6. Laboratory has a complaint redressal system. Discrepancies if any in the test report must be brought to notice within 7 days of issue of test report.

7. This report shall not be used as evidence in the court of law and shall not be reproduced except in full, without prior written approval of Siddhi Green Excellence Pvt. Ltd.

*** End of Report ***

Page 1 of 1

Format No.: SC/LAB/F/Report-11 Issue No. :01 Issue Date: 30-06-2020 Revision No : 01 Revision Date : 09-04-2022

GUJARAT'S
1ST PLATINUM
CERTIFIED
NEW GREEN
INTERIORS
BY IGBC

: Regd. Office :

"Kamal Arcade - The Vertical Suncllock" Comm. Plot No. C-3/3,
GIDC Station Road, Ankleshwar - 393 002. Dist. Bharuch,
Gujarat State, (India). Tele. : 02646 - 224805, 223805
E-mail : siddhi.ank@gmail.com

: Dahej Off. :

"SANSKAR AVENUE" Shop No. GF 37, P.O. Jolva,
Ta. Vagra, Dist. Bharuch. Tele : 02641 - 254041

www.siddhigreen.com